

The Township of



# Rideau Lakes

**Construction of Pickleball Courts at  
Ronald E Holman Complex -  
ADDENDUM #1**

**A1-PW2026-13**

## A1-PW2026-13

This addendum is being released to clarify questions received on RFP 2026-13 for the construction of pickleball courts at the Ronald E Holman Complex.

Please see questions received and responses noted below.

1. Q: I have one question: Are there any footing details/requirements for the pickleball posts that I can provide the supplier?

A: End posts to be placed in Sono tube 48" deep with top 6" below grade, poured with 30 MPa concrete.

2. Q: Would you accept an alternate acrylic coating manufacturer for this project?

A: Yes, provided alternate is equal to Sports Master product listed as standard of acceptance.