

The Township of



# Rideau Lakes

**Replacement of Structural Columns at  
Elgin Municipal Complex - ADDENDUM #1**

**A1-PW2026-16**

## A1-PW2026-16

This addendum is being released to clarify questions received on RFQ PW2026-16 for the replacement of structural columns at the Elgin Municipal Complex, and to note a small change to the Scope of Work section on page 4.

Revisions are to the original RFQ document with closing date of April 30, 2026.

In the "Scope of Work" section on page 4, in the summary of scope, point 2 reads "Ensure a minimum of 6" of existing column is above grade". Please disregard this point as the existing concrete footing bases are sufficient.

Please see questions received and responses noted below.

1. Q: If you could provide some details on specifications, that would be helpful to get accurate pricing.

A: Standard of acceptance is product by Elite Trim Works. <https://ca.elitetrimworks.com/collections/structural-fiberglass-columns>. Product spec sheet provided, see RFQ for column details, steel columns wrapped in wood will not be accepted.

2. Q: Can you also clarify what "3.25k" means in regards to the columns?

A: 3.25k refers to loading each column will support, 3.25k = 3.25 kip (or 3250lbs).